

ADDENDUM NO.2

TO ALL BIDDERS FOR CONTRACT
EAST END AVENUE PIPE REHABILITATION

RVE PROJECT NUMBER: 1335M011

TOWNSHIP OF NEPTUNE SEWERAGE AUTHORITY
MONMOUTH COUNTY, NJ

You are hereby notified in accordance with the paragraph entitled “Addenda, Bid Specification Challenges and Interpretations” of the above captioned project that the following has been issued to clarify the meaning of the specifications and the conditions and specifications set forth in said addendum are to be considered as binding as if the same was set forth in the original contract documents.

The following revisions, corrections and/or clarifications are hereby made to the contract plans and/or specifications:

1. Analytical testing has been completed on the existing pipeline coating to be removed from the Site (summarized below). The results of the testing indicate that the coating has a lead content below 6.3 parts per million and is not considered a lead-based paint (LBP) per US EPA guidelines. Existing coating and wash water used for removal may be treated as a non-hazardous material for disposal purposes.

Sample Number	Material	Location	PPM	% Lead By Weight
LBP-001	Blue Paint on Metal Pipe	TNSA Wastewater Pipe West – Along East End Avenue	6.3	<0.0063
LBP-002	Blue Paint on Metal Pipe	TNSA Wastewater Pipe Center – Along East End Avenue	6.3	<0.0063
LBP-003	Blue Paint on Metal Pipe	TNSA Wastewater Pipe East – Along East End Avenue	6.3	<0.0063

This information is provided to inform / clarify disposal procedures only. **The required containment / environmental protection measures for coating removal and application procedures as specified in the Contract Documents are unchanged. The contractor remains responsible for no debris or release to the adjacent river.**

In addition, Contractors must adhere to proper PPE for their workers and are required for the onsite Health and Safety Plan for their workers

2. The following changes to the Contract Documents are included with this Addendum:
 - Remove and replace the entirety of the Scope of Work (2 pages) with the attached ADDENDUM 2 Scope of Work (2 pages)
 - Remove and replace the entirety of Section 099000 “Painting and Coating” (8 pages) with the attached ADDENDUM 2 Section 099000 “Painting and Coating” (8 pages)

The bid opening date / time will remain as **Tuesday, May 12th, 2026, at 10:30 AM**. The bid opening location will remain as the Township of Neptune Sewerage Authority at **634 Old Corlies Avenue, Neptune, NJ 07753**.